

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30.09.2025

It is certified that an inspection team headed by Ashwani Kumar

(Name of Officers with designation) from Junior Engineer PHED

inspected the Rajiv Gandhi Model Day Boarding School Amlehar Distt. Hamirpur (Nadaun constituency)

(Name & Address of the school) on 30.09.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1955 dated 01/10/2025

of ..... (PHED Lab) certified that the

Rajiv Gandhi Model Day Boarding School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 29.09.2026

Signature with Seal: .....

Name : .....

Designation : .....

Name & Address of the Office / Department : .....

To Principal (Rajiv Gandhi Model Day Boarding School Amlehar (Name & Address of the Institution) Distt. Hamirpur (Nadaun constituency))

DEPARTMENT OF  
Public Health & Engineering  
Hamirpur  
Sub Division Nadaun

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Ashwani Kumar  
Dy. Director of School Education  
(Secondary) Distt. Hamirpur

Self attested

Amrita  
Principal  
Govt. Sr. Sec. School, Amlehar  
Distt. Hamirpur (H.P.)  
D.D.O. Code: 226

**HIMACHAL PRADESH JAL SHAKTI VIBHAG**  
**WATER TESTING LABORATORY**  
**JAL SHAKTI SUB-DIVISION NADAUN, DISTT. HAMIRPUR**

Sr. No. 1955

Lab. Ref. No SHMR NABL-DWT-00629

Dated 01/10/25

Name & Address of Sender.....

Division Nadaun

Govt. Sr. Sec. School Amlehar

Sub Div Nadaun

Section.....

J.E. ....

1. Name of Scheme .....
2. Nature of Source Tap Water
3. Place of Collection G.S.S.S Amlehar
4. Date and Time receipt of Laboratory 30/09/25
5. Date and Time of collection of Examination 30/09/25
6. Nature of Sample :- 
 

1. Raw water	2. Chlorinated water	3. Filtered water
4. Distribution System	5. Hand Pump	6. Well

(A) PHYSICAL TESTS				
Sr. No.	Parameter	Acceptable	Permissible Limit	Result of Sample
1	Temperature			
2	Turbidity (NTU)	1.00 NTU	5.00 NTU	<u>1.1</u> N.T.U.
3	Colour	5 HU	15 HU	<u>3</u> Hazen Unit
4	Taste	Un-objectionable	Objectionable	<u>Un-objectionable</u>
5	Odour	Agreeable	Disagreeable	<u>Agreeable</u>
6	PH Value	6.5 - 8.5	No Relaxation	<u>8.4</u>
7	TDS/Conductivity	500 mg/l	2000 mg/l	<u>417</u> mg/l
(B) CHEMICAL TESTS				
1	Residual Chlorine	0.2 ppm	1.0 ppm	<u>0.2</u> ppm
2	Total Hardness mg/l Caco3	200 mg/l	600 mg/l	<u>224</u> mg/l
3	Total alkalinity	200 mg/l	600 mg/l	<u>138</u> mg/l
4	Chloride mg/l	250 mg/l	1000 mg/l	<u>36</u> mg/l
5	Nitrates mg/l	45 mg/l	No Relaxation	
6	Iron mg/l	0.3 mg/l	1.0 mg/l	
7	Calcium mg/l	75 mg/l	200 mg/l	<u>26.4</u> mg/l
8	Fluoride mg/l	1.0 mg/l	1.5 mg/l	
9	Sulphate mg/l	200 mg/l	400 mg/l	
10	Arsenic mg/l	0.01 mg/l	0.05 mg/l	
(C) BACTERIOLOGICAL TESTS				
	Total No. of coliforms	Nil	Nil	<u>NIL</u> MPN/100ml
	Focal Coliforms			
	F-Coil/100ml	Nil	Nil	

*Self  
at  
lab*

*Principal  
Govt. Sr. Sec. School,  
Distt. Hamirpur (H.P.)  
D.D.O. CoeKS6*

Water is safe on above parameters ✓

Radhika  
Assistant (Chemist)

Assistant Engineer  
Jal Shakti Vibhag  
Sub Division Nadaun  
Assistant Engineer,  
Jal Shakti Sub-Divn. Nadaun